



Government Of Bihar

Regional Water Testing Laboratory

Public Health Engineering Department,

Bhagalpur

Sample Collected By- Staff (School)	Date of Sample Collection - 02.06.2021
Sample Submitted By- Staff (School)	Date of Sample Submission- 04.06.2021
Ref.- EE 1115 dt.07.06.2021	Date of Sample Testing- 05.06.2021

PHYSICO-CHEMICAL & BACTERIOLOGICAL TEST REPORT

S.No.	Location				Physico - Chemical and Bacteriological Parameters																Remarks
	Block	Panchayat	Village	Habitation	Name	pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alka.	Fe	NO ₃	SO ₄	F	As	Microbial	
1	Saraswati Vidya Mandir Pakaralla ,Kahalgau, Bhagapur					7.73	0.65	260.0	158.0	66.4	14.6	3.55	12.0	62.0	0.23	4.23	5.0	0.61	BDL	NT	
	Desirable Limit*				6.5-8.5	1.0	-	500	300	75	30	250	200	1.0	45.0	200	1.0	0.01	-		
	Permissible Limit* in absence of alternate source				NR	5.0	-	2000	600	200	100	1000	600	NR	NR	400	1.5	NR	**		

Memo No.

RL-44

Copy Forwarded To : 1. Executive Engineer, P.H.Division Bhagalpur east, for kind information and necessary action.

2. Saraswati Vidya Mandir Kahalgau, for kind information and necessary action.

Date 07.06.2021

Lab. Assistant

7.06.21

सावित्र

महादेव राकेशलाल कटार
सारस्वती विद्या मंदिर
एकदलाला कालगीव भागलपुर

At.
Binod Kumar Pandey
23.06.2021

Chemist

M.S.L.K.S.V.M. Pakartalla, Kahalgau,
Bhagalpur. At. to CBSE DELHI
SCH. CODE 655589, AFF No-330593